



1. SINCE STREET LIGHTING LOADS ARE CONTINUOUSLY ENERGIZED FOR LONG PERIODS, THE CONNECTED LOAD SHOULD NOT EXCEED 80% OF THE FUSE RATING. THE LOAD CALCULATIONS SHOULD BE BASED ON THE TOTAL AMPERE RATING OF THE BALLASTS, TRANSFORMERS, OR REACTORS AND NOT ON THE WATTAGE OF THE LAMPS.

MAYSTEEL LLC CLAIMS PROPRIETARY RIGHTS IN THE INFORMATION DISCLOSED HEREON. THIS DRAWING IS FURNISHED IN CONFIDENCE ON THE EXPRESS UNDERSTANDING THAT IT OR ANY REPRODUCTION THEREOF WILL BE USED SOLELY FOR THE MANUFACTURE OR PROCUREMENT OF PARTS TO BE FURNISHED TO MAYSTEEL LLC.

**Maysteel**  
Electric Utility  
Products & Enclosures

TITLE

CONNECTIONS FOR TYPE MR-KD  
1P RELAY RATED 60 A 250V 60C

**A**

A	LOG NO. 0832	1-19-98	DRAWN	APPROVED	SCALE	DWG NO
REV LTR	DESCRIPTION	DATE	3-27-95 GMM	1-19-98 CKR	--	33013000