



1. THE RECEPTACLE IS ADJUSTABLE FOR NORTH ORIENTATION IN ACCORDANCE WITH THE REQUIREMENTS OF EEL-STANDARD NO. TDJ-148.
2. THE PHOTO-CONTROL SHOULD OPERATE TO ENERGIZE THE RELAY COIL DURING THE ON SCHEDULE FOR THE STREET LIGHTING CIRCUIT.
3. SINCE STREET LIGHTING LOADS ARE CONTINUOUSLY ENERGIZED FOR LONG PERIODS, THE CONNECTED LOAD SHOULD NOT EXCEED 80% OF THE FUSE RATING. LOAD CALCULATIONS SHOULD BE BASED ON THE RATING OF THE BALASTS, TRANSFORMERS, OR REACTORS AND NOT ON THE WATTAGE OF THE LAMPS.

MAYSTEEL LLC CLAIMS PROPRIETARY RIGHTS IN THE INFORMATION DISCLOSED HEREON. THIS DRAWING IS FURNISHED IN CONFIDENCE ON THE EXPRESS UNDERSTANDING THAT IT OR ANY REPRODUCTION THEREOF WILL BE USED SOLELY FOR THE MANUFACTURE OR PROCUREMENT OF PARTS TO BE FURNISHED TO MAYSTEEL LLC.

Maysteel

Electric Utility
Products & Enclosures

TITLE
CONNECTIONS FOR TYPE MR-UG 2P RELAY RATED
60A 240V 60C WITH PHOTO CONTROL UNIT

A

B	CN 31125700 "B"	3-28-95
REV LTR	DESCRIPTION	DATE

DRAWN
3-28-95 GMM

APPROVED
4-10-97 JRF

SCALE
--

DWG NO
31125700