



1. THE WEATHERPROOF CASE MUST BE EFFECTIVLY GROUNDED.
2. THE RECEPTACLE IS ADJUSTABLE FOR NORTH ORIENTATION.
3. THE PHOTO CONTROL SHOULD OPERATE TO ENERGIZE THE RELAY COIL DURING THE ON SCHEDULE FOR THE STREET LIGHTING CIRCUIT.
4. STREET LIGHTING LOADS ARE CONTINUOUSLY ENERGIZED FOR LONG PERIODS, AND THE CONNECTED LOAD SHOULD NOT EXCEED 80% OF THE FUSE RATING.
5. THIS RELAY IS RECOMMENDED FOR SWITCHING THE POWER SUPPLY TO BALLASTS FOR A STREET LIGHTING LOAD WITH 85% MINIMUM POWER FACTOR.

MAYSTEEL LLC CLAIMS PROPRIETARY RIGHTS IN THE INFORMATION DISCLOSED HEREON. THIS DRAWING IS FURNISHED IN CONFIDENCE ON THE EXPRESS UNDERSTANDING THAT IT OR ANY REPRODUCTION THEREOF WILL BE USED SOLELY FOR THE MANUFACTURE OR PROCUREMENT OF PARTS TO BE FURNISHED TO MAYSTEEL LLC.

Maysteel
Electric Utility
Products & Enclosures

TITLE MR-WO SPEC. 6585 2POLE 30A
WIRING DIAGRAM

A

B	LOG NO. 1518	12-9-98
A	LOG NO. 0881	1-24-98
REV LTR	DESCRIPTION	DATE

DRAWN 3-24-95 gmm

APPROVED 12-10-98 CKR

SCALE --

DWG NO 31187200